

# ORGANISATION INTERNATIONALE DE MÉTROLOGIE LÉGALE

---



## INTERNATIONAL RECOMMENDATION

---

### **Discontinuous totalizing automatic weighing instruments (totalizing hopper weighers)**

**Part 2: Test report format**

Instruments de pesage totalisateurs discontinus à fonctionnement automatique  
(peseuses totalisatrices à trémie)  
Partie 2: Format du rapport d'essai

OIML R 107-2

Edition 1997 (E)

## CONTENTS

<b>Foreword .....</b>	<b>3</b>
<b>Introduction .....</b>	<b>4</b>
<b>Identification of the instrument .....</b>	<b>5</b>
<b>General information concerning the pattern .....</b>	<b>7</b>
<b>Checklist .....</b>	<b>10</b>
Summary of the checklist .....	10
Checklist .....	12
<b>Test report .....</b>	<b>23</b>
Test equipment used for pattern evaluation .....	23
Configuration for test .....	24
Explanatory notes .....	25
Summary of test report .....	26
<b>1 Zero-setting device .....</b>	<b>27</b>
1.1 Zero-setting modes .....	27
1.2 Range of zero-setting .....	27
1.3 Accuracy of zero-setting .....	27
1.4 Additional zero-setting modes .....	28
1.5 Zero offset interlock .....	29
<b>2 Material tests .....</b>	<b>30</b>
2.1 Material testing (separate verification method) .....	30
2.2 Integral verification method .....	35
<b>3 Warm-up time .....</b>	<b>41</b>
<b>4 Influence quantities .....</b>	<b>42</b>
4.1 Static temperatures .....	42
4.2 Damp heat, steady state .....	52
4.3 Mains power supply voltage variation (AC) .....	58
4.4 Battery power supply voltage variation (DC) .....	60
<b>5 Disturbances .....</b>	<b>62</b>
5.1 Voltage dips and short interruptions .....	62
5.2 Electrical fast transients/burst immunity .....	64
5.3 Electrostatic discharges .....	69
5.4 Electromagnetic susceptibility .....	75
<b>6 Span stability .....</b>	<b>79</b>

## **FOREWORD**

The International Organization of Legal Metrology (OIML) is a worldwide, intergovernmental organization whose primary aim is to harmonize the regulations and metrological controls applied by the national metrological services, or related organizations, of its Member States.

The two main categories of OIML publications are:

- 1) **International Recommendations (OIML R)**, which are model regulations that establish the metrological characteristics required of certain measuring instruments and which specify methods and equipment for checking their conformity; the OIML Member States shall implement these Recommendations to the greatest possible extent;
- 2) **International Documents (OIML D)**, which are informative in nature and intended to improve the work of the metrological services.

OIML Draft Recommendations and Documents are developed by technical committees or subcommittees which are formed by the Member States. Certain international and regional institutions also participate on a consultation basis.

Cooperative agreements are established between OIML and certain institutions, such as ISO and IEC, with the objective of avoiding contradictory requirements; consequently, manufacturers and users of measuring instruments, test laboratories, etc. may apply simultaneously OIML publications and those of other institutions.

International Recommendations and International Documents are published in French (F) and English (E) and are subject to periodic revision.

OIML publications may be obtained from the Organization's headquarters:

Bureau International de Métrologie Légale  
11, rue Turgot - 75009 Paris - France  
Telephone: 33 (0)1 48 78 12 82 and 42 85 27 11  
Fax: 33 (0)1 42 82 17 27  
E-mail: [biml@oiml.org](mailto:biml@oiml.org)

\*  
\* \*

This publication - reference OIML R 107-2, edition 1997 (E) - was developed by the OIML subcommittee TC 9/SC 2 *Automatic weighing instruments*. It was sanctioned by the International Conference of Legal Metrology in 1996.

## INTRODUCTION

The *Test report format* aims at presenting, in a standardized format, the results of the various tests and examinations to which a pattern of a discontinuous totalizing automatic weighing instrument (totalizing hopper weigher) shall be submitted with a view to its approval.

The *Test report format* consists of two parts, the *Checklist* and the *Test report*.

- The *Checklist* is a summary of the examinations carried out on the instrument. It includes the conclusions of the results of the test performed, and experimental or visual checks based on the requirements of OIML R 107-1. The words or condensed sentences aim at reminding the examiner of the requirements in OIML R 107-1 without reproducing them.
- The *Test report* is a record of the results of the tests carried out on the instrument. The test report forms have been produced based on the tests detailed in OIML R 107-1.

The “information concerning the test equipment used for pattern evaluation” shall cover all test equipment which has been used in determining the test results given in a report. The information may be a short list containing essential data (name, type, reference number for the purpose of traceability). For example:

- Verification standards (accuracy, or accuracy class, and no.);
- Simulator for testing of modules (name, type, traceability and no.);
- Climatic test and static temperature chamber (name, type and no.);
- Electrical tests, bursts (name of the instrument, type and no.);
- Description of the procedure of field calibration for the test of electromagnetic susceptibility.

All metrology services or laboratories evaluating patterns of discontinuous totalizing automatic weighing instruments according to OIML R 107-1 or to national or regional regulations based on OIML R 107-1 are strongly advised to use this *Test report format*, directly or after translation into a language other than English or French. Its direct use in English or in French, or in both languages, is even more strongly recommended whenever test results may be transmitted by the country performing these tests to the approving authorities of another country, under bi- or multi-lateral cooperation agreements. In the framework of the *OIML Certificate System for measuring instruments*, use of the *Test report format* is mandatory.

### *Note concerning page numbering in this publication*

In addition to the sequential numbering "R 107-2 page .." at the bottom of each page, a space has been left at the top of each page (starting on page 5) for numbering the pages of reports established following this model. In particular, some tests (e.g. metrological performance tests) shall be repeated several times, each test being reported individually on a separate page following the relevant format. For a given report, it is advisable to complete the sequential numbering of each page by indicating the total number of pages in the report.

## IDENTIFICATION OF THE INSTRUMENT

Application No: .....

Report date: .....

Pattern designation: .....

Manufacturer: .....

Serial No: .....

Manufacturing documentation

(Record as necessary to identify the equipment under test)

Simulator documentation

System or module name	Drawing number or software reference	Issue level
.....	.....	.....
.....	.....	.....
.....	.....	.....

## Simulator function (summary)

Simulator description and drawings, block diagram etc. should be attached to the report if available

IDENTIFICATION OF THE INSTRUMENT (continued)

Application No: .....

Report date: .....

Pattern designation: .....

Manufacturer: .....

Description or other information pertaining to identification of the instrument (attach photograph here if available):

GENERAL INFORMATION CONCERNING THE PATTERN

Application No: .....

Manufacturer: .....

Applicant: .....

Instrument category: .....

Testing on:  Complete instrument  Module (\*)

Pattern designation: .....

Accuracy class:

0.2  0.5  1  2

Min =   $\Sigma_{\min} =$

Max =

T = +  T = -  d =  d<sub>t</sub> =

U<sub>nom</sub> (\*\*) =  V U<sub>min</sub> =  V U<sub>max</sub> =  V f =  Hz Battery, U =  V

Zero-setting device:

Nonautomatic

Semi-automatic

Automatic

Initial zero-setting

Initial zero-setting range:  % Temperature range:  °C

---

(\*) The test equipment (simulator or part of a complete instrument) connected to the module shall be defined in the test form(s) used

(\*\*) The voltage U<sub>nom</sub> shall be as defined in IEC 1000-4-11 (1994) section 5

GENERAL INFORMATION CONCERNING THE PATTERN (continued)

Printer:  Built-in  Connected  Not present but connectable  No connection

Instrument submitted: .....

Identification No: .....

Connected equipment: .....

Interfaces  
(number, nature): .....

Load cell:

Manufacturer:

OIML R 60 certificate of  
conformity. Please tick and  
if "Yes" supply certificate  
number.

Yes

Certificate number

No

Type:

Capacity:

Number:

Classification symbol:

Remarks: see following page

Date of report: .....

Evaluation period: .....

Observer: .....

Report page ... / ...

GENERAL INFORMATION CONCERNING THE PATTERN (continued)

Use this space to indicate additional remarks and/or information: other connected equipment, interfaces and load cells, choice of the manufacturer regarding protection against disturbances, etc.

**CHECKLIST**

For each test, the "SUMMARY OF THE CHECKLIST" and the "CHECKLIST" shall be completed according to this example:

Passed	Failed
X	
	X
/	/

**SUMMARY OF THE CHECKLIST**

Requirement	Passed	Failed	Remarks
Metrological requirements R 107-1 clause 2			
Technical requirements R 107-1 clause 3			
Requirements for electronic instruments R 107-1 clause 4			
Metrological controls R 107-1 clause 5			
Test methods R 107-1 clause 6			
Test report			
<b>OVERALL RESULT</b>			

Report page ... / ...

**SUMMARY OF THE CHECKLIST (continued)**

Use this page to detail remarks from the summary of the checklist

## CHECKLIST

Application No: .....

Pattern designation: .....

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
2	Metrological requirements				
2.2	Maximum permissible errors				
2.2.1	A.6.2	Maximum permissible errors for automatic weighing for each class for loads not less than $\sum_{min}$ : do not exceed values in R 107-1 Table 1 rounded to nearest $d_t$			
	A.8.3	Maximum permissible errors for influence factor tests: do not exceed values in R 107-1 Table 2, digital indications and printed results shall be corrected for rounding error and errors determined with accuracy of at least 0.2 $d_t$			
2.3	Observe	Form of scale interval: $1 \times 10^k$ , $2 \times 10^k$ or $5 \times 10^k$	Note		
2.4	Observe	Totalization scale interval: $0.01 \% \leq d_t \leq 0.1 \% \text{ of Max}$	Note		
2.5	Observe	Minimum totalized load: $\sum_{min} \geq \text{Min}$ $\sum_{min} \geq 1000 d_t$ for class 0.2 or 400 $d_t$ for class 0.5 or 200 $d_t$ for class 1 or 100 $d_t$ for class 2			
2.6	A.7.2	Agreement between indicating and printing devices			
2.7	Influence quantities				
2.7.1	A.8.3.1	Static temperature			
2.7.2	A.8.3.3	Mains power supply (AC)			
2.7.3	A.8.3.4	Battery power supply (DC)			
3	Technical requirements				
3.1	Observe	Suitability for use: design to suit intended materials and usage			
3.2	Security of operation:				
3.2.1	Observe	<ul style="list-style-type: none"> <li>- Maladjustment prevented</li> <li>- Operation unaffected by incomplete discharge</li> <li>- Inhibition of usage at loads <math>&gt; \text{Max}</math></li> <li style="text-align: center;"><math>&lt; \text{Min}</math></li> </ul>			
3.2.2					
3.2.3 (a)					
3.2.3 (b)					
3.2.4	A.7.3	Adjustment prevented in auto mode			
3.2.5	Observe	Dust extraction: shall not affect measurement			

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
3.2.6	A.6.1	Zero-setting device: Observe Instrument tare weigh after each discharge, or Observe Instrument does not tare weigh after each discharge in which case: A.7.7 An interlock is provided to stop automatic operation if zero indicated varies by: - 1 $d_t$ for instruments with auto zero-setting - 0.5 $d_t$ for instruments with semi-auto or non-auto zero-setting A.6.1.3 Accuracy of zero-setting is $\pm 0.25$ of smallest scale interval of all indicating devices and shall have: A.6.1.2 Accuracy range of adjustment not exceeding 4 % of maximum capacity	Confirm Confirm Confirm Confirm Confirm		
3.2.7	Observe	Fraudulent use: no characteristics likely to facilitate fraudulent use			
3.3	Observe	Instrument with a control indicating device shall have facility to support standard weights in accordance with R 107-1 Table 3	Confirm		
3.4		Totalization indicating and printing devices: Observe Totalization devices present: Principal Supplementary Partial Combined Printer	Note Note Note Note Note		
3.4 (a)	A.7.4	On instruments with printing device: not possible to reset principle totalization indication without auto printout and	Confirm		
3.4 (b)	A.7.4	Auto printout if interrupted	Confirm		
3.4.1	Observe	A totalization indicating and printing device shall allow reliable, simple and unambiguous reading of results by simple juxtaposition and bear name or symbol of the appropriate unit of mass	Confirm		
3.4.2	Observe	Except supplementary totalization devices, scale interval of all devices shall be same	Confirm		
3.4.3	Observe	For supplementary device, scale interval $> 10 d_t$	Confirm		
3.4.4	Observe	Indicating devices may be combined so that indication is on demand, if so it is to be clearly identified	Confirm		
3.5	Observe	Ancillary devices: do not affect totalization representing a bulk load transaction			

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks		
3.6	Sealing:						
			Location		Note		
			Form		Note		
3.7	Descriptive markings						
3.7.1	Markings shown in full:						
	Observe	identification mark of the manufacturer					
		identification mark of the importer (if applicable)					
		serial number and type designation of the instrument					
		product(s) designation					
		control scale interval (if applicable) - g or kg or t					
		electrical supply voltage - V					
		electrical supply frequency - Hz					
		working fluid pressure (if applicable) - kPa or bar					
3.7.2	Markings shown in code:						
	Observe	pattern approval sign in accordance with national requirements					
		indication of the accuracy class: 0.2, 0.5, 1 or 2					
		maximum capacity Max - g or kg or t					
		minimum capacity Min - g or kg or t					
		minimum totalized load $\Sigma_{\min}$ - g or kg or t					
		totalization scale interval $d_t$ - g or kg or t					
3.7.3	Supplementary markings:						
	Observe	temperature range					
		special applications clearly marked					
3.7.4	Presentation of descriptive markings:						
	Observe	indelible					
		easily readable					
		grouped together in a clearly visible place					
		possible to seal the plate unless removal will result in destruction					
3.8	Verification marks						
3.8.1	Observe	Position:					
		cannot be removed					
		easy application					
		visibility without the instrument or its protective covers being removed					

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
3.8.2		Verification mark support which ensures conservation of the marks			
4	Requirements for electronic instruments				
4.1	General requirements				
4.1.1	Observe	Rated operating conditions: errors do not exceed mpe			
4.1.2		Disturbances: electronic instruments shall be designed and manufactured so that:			
4.1.2 (a)		- significant faults do not occur, or			
4.1.2 (b)		- significant faults are detected and acted upon			
4.1.3	Observe	Durability: requirements of 4.1.1 and 4.1.2 shall be met durably			
4.1.4	Observe	Evaluation for compliance: instrument has passed examination and test specified in Annex A			
4.2	Observe	Application: requirements in 4.1.2 may be applied separately to:	Note		
4.2.1 (a)		- each individual cause of significant fault, and/or	Note		
4.2.1 (b)		- each part of the electronic instrument	Note		
4.2.2		Choice is made by the manufacturer	Note		
4.3	Functional requirements:				
4.3.1	Observe	Acting upon a significant fault:	Note below		
		Visual indication, or			
		audible indication is provided and is continuous until user takes action or the fault disappears			
4.3.2	Observe	Totalized load information is retained when a significant fault occurs			
4.3.3	Influence quantities:				
	A.8.3	Instrument complies with requirements of R 107-1 subclause 2.7, and			
		A.8.3.2 Damp heat steady state			
4.3.4	A.8.4	Disturbances			
	A.8.4.1	Voltage dips and short interruptions			
	A.8.4.2	Electrical fast transients/burst immunity			
	A.8.4.3	Electrostatic discharge			
	A.8.4.4	Electromagnetic susceptibility			

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
4.3.5	A.7.1	Warm-up time: no indication or transmission of information; auto operation shall be inhibited			
4.3.6	Observe	Interface: when fitted no effect on instrument			
4.3.7	A.7.6	Mains power supply failure:  Metrological information to be retained for at least 24 hours  Switch-over to emergency power supply shall not cause significant fault			
4.3.8	A.7.5	Battery power supply failure (voltage drops below the manufacturer's specified value):  Instrument continues to function correctly  Instrument is automatically disabled			
4.4		Examination and tests			
4.4.1		Instrument examined to obtain general appraisal of design and construction			
4.4.2		Instrument meets the requirements in Annex A			
4.4.3	A.9	Span stability  The maximum allowable variation in the errors of indication shall not exceed half the absolute value of the maximum permissible error in R 107-1, 2.2.2 Table 2 for the test load for any of the n measurements  Where the difference of the results indicates a trend more than half the allowable variation specified above the tests shall continue until the trend comes to rest, or reverses itself, or until the error exceeds the maximum allowable variation		Note	
5		Metrological controls			
5.1		Pattern evaluation			
5.1.1		Documentation includes:  metrological characteristics of the instrument specifications of the instrument technical information and data functional description drawings, diagrams and general software information as applicable, to explain construction and operation fractions p (modules tested separately) other documentation	Confirm		

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks		
5.1.2	General requirements						
	Instruments available for test as follows:						
	fully operational at a typical site		Confirm				
	for laboratory simulation testing		Confirm				
	evaluation consists of tests specified in 5.1.3						
5.1.3	Pattern evaluation						
	Observe	Documents examined and tests carried out to verify that instrument complies with:					
		requirements specified in clause 2					
		technical requirements in clause 3					
		acceptance of test reports from another authority		Note			
		instruments that can operate as nonautomatic shall comply with OIML R 76-1, class III or IIII		Note			
5.1.3.1	A.6.2	Material tests					
		Instruments subjected to in-situ material tests in accordance with:		Indicate below			
		separate verification method as in A.6.2.2, or					
		integral verification method as in A.6.2.3					
		when integral control instrument method used, weighing test as in A.6.2.3.1		Confirm			
		In-situ material tests shall be done as follows:					
		in accordance with descriptive markings		Confirm			
		under rated operating conditions for the instrument		Confirm			
		not less than three material tests shall be conducted:		Confirm			
		- one at minimum capacity					
		- one at maximum capacity					
		- one at close to minimum totalized load					
		each test conducted at maximum rate of weighing cycles per hour		Confirm			
		with a test load representative of the range and type of product or a product for which the instrument is specified		Confirm			
		quantity not less than minimum totalized load as marked on the instrument		Confirm			
		when quantity equal to minimum totalized load can be totalized in less than five weighing cycles, additional test required, five at maximum capacity and five at minimum capacity		Note			

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
		equipment near the instrument, e.g. conveyors, dust collection system in use in normal operation of the instrument, shall be in use	Note		
		if instrument can divert weighed material, the test program shall be performed for each alternative, unless hopper not affected	Note		
		when load receptor cannot be loaded with sufficient standard weights, instrument shall be subjected to material tests by separate verification method, in which case an appropriate control instrument shall be available	Note method		
		errors for automatic weighing: difference between conventional true value of test load as defined in 6.2.2 or 6.2.3, and indicated weight observed and recorded as defined in 6.2.1 or 6.3.2	Confirm		
		maximum permissible error shall be as specified in 2.2.1 Table 1 for initial verification	Confirm		
5.1.3.2	A.8	Simulation tests			
		Influence quantities shall be applied during simulation tests in a manner that reveals alteration in accordance with: R 107-1, 2.7 for all instruments R 107-1, 4 for electronic instruments, and	Confirm		
		when conducting tests on load cells or an electronic device equipped with an analogue component, mpe shall be 0.7 times value in R 107-1 Table 2, and	Note		
		if the metrological characteristics of the load cell or other major component have been evaluated in accordance with OIML R 60 or any other Recommendation, that evaluation shall be used to aid pattern evaluation if requested by applicant, and	Note		
		as requirements in this clause apply only to instrument submitted for pattern evaluation and not verification, means to determine whether mpe or maximum allowable variation has been exceeded shall be agreed with applicant for example by: - adaption of totalization indication to higher resolution - use of change point weights - any mutually agreed method	Note method		
5.1.4	Observe	Provision of means for testing: applicant may be required to provide material, handling equipment, personnel, and control instrument	Note		
5.1.5	Observe	Instrument submitted may be tested at: premises of metrological authority, or any other mutually agreed place	Note		

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
5.2	Initial verification				
5.2.1		Instruments shall comply with R 107-1, 2 (except 2.7) and 3 for any products for which they are intended under normal conditions, and	Confirm		
		test shall be carried out by metrological authority, in-situ, normal installation. Instrument installed such that automatic weighing is same for testing as for transaction, and	Confirm		
		in manner that prevents unnecessary commitment of resources and avoids duplicating tests previously performed for pattern evaluation under R 107-1, 5.1.3 results of such observed tests may be used	Confirm		
5.2.1.1		instruments that can operate as nonautomatic shall comply with OIML R 76-1, class III or IIII	Confirm		
5.2.1.2	Material tests				
		Instruments subjected to in-situ material tests in accordance with:			
		separate verification method as in A.6.2.2, or	Confirm		
		integral verification method as in A.6.2.3	Confirm		
		when integral control instrument method used, weighing test as in A.6.2.3.1	Confirm		
	In-situ material test shall be done as follows:				
		in accordance with descriptive markings	Confirm		
		under rated operating conditions for the instrument	Confirm		
		not less than three material tests shall be conducted: - one at minimum capacity - one at maximum capacity - one at close to minimum totalized load	Confirm		
		each test conducted at maximum rate of weighing cycles per hour	Confirm		
		with a test load representative of the range and type of product or a product for which instrument specified	Confirm		
		quantity not less than minimum totalized load as marked on the instrument	Confirm		
		when quantity equal to minimum totalized load can be totalized in less than five weighing cycles, additional test required, five at maximum capacity and five at minimum capacity	Note		
		equipment near the instrument, e.g. conveyors, dust collection system in use in normal operation of the instrument, shall be in use	Note		
		if instrument can divert weighed material, the test program shall be performed for each alternative, unless not affected. Testing for full range need only be done for one discharge facility	Note		
		when load receptor cannot be loaded with sufficient standard weights, instrument shall be subjected to material tests by separate verification method, in which case an appropriate control instrument shall be available	Note method		

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
5.2.2		errors for automatic weighing: difference between conventional true value of test load as defined in 6.2.2 or 6.3.3, and indicated weight observed and recorded as defined in 6.2.1 or 6.3.2	Confirm		
		maximum permissible error shall be as specified in 2.2.1 Table 1 for initial verification	Confirm		
		Provision of means for testing: applicant may be required to provide material, handling equipment, personnel and control instrument	Note		
6		Test methods			
6.1		Control instrument and test standards: shall ensure the checking of a test load to an error not greater than:  a) one third of the mpe for automatic weighing when control instrument or device used for control purposes is verified immediately prior to material tests, or  b) one fifth of the mpe in all other cases	Note mpe		
6.2		Separate verification method			
6.2.1		Indicated weight: test load weighed as automatic bulk to bulk weighing operation, the indicated weight value of the principal totalization indicating device observed and recorded	Confirm		
6.2.2		Mass of the test load: test load weighed on control instrument and the result considered as true value of mass of test load	Confirm		
6.3		Integral verification method:  Instrument being verified is used to determine the conventional true mass of test load	Confirm		
		Integral method shall be conducted using either:  a) partial indicating device with standard weights to assess the rounding error, or  b) an appropriately designed control indicating device	Note below		
		Interruption of automatic operation:  Automatic weighing operation of test load shall be initiated following the same procedure for weighing bulk to bulk. However, automatic operation shall be interrupted twice during each weighing cycle necessary to weigh a sub-division of the test load. Automatic operation shall not be interrupted if the instrument is installed in an air-enclosed system	Confirm		

Requirement of R 107-1	Test procedure	Requirement summary - refer to OIML R 107-1 for details	Passed	Failed	Remarks
6.3.1.1		Predischarge (gross) interrupt:  After load receptor has been loaded and instrument has automatically processed gross weight, automatic operation shall be interrupted. When load receptor has stabilized, the gross weight indicated or determined by balancing with standard weights shall be recorded and instrument switched back to automatic operation	Confirm		
6.3.1.2		Postdischarge (tare) interrupt:  After load receptor has been loaded and instrument has automatically processed tare weight, automatic operation shall be interrupted. When load receptor has stabilized, the tare weight indicated or determined by balancing with standard weights shall be recorded and instrument switched back to automatic operation	Confirm		
6.3.2		Indicated weight:  Principal totalization indicating device shall be used in obtaining the indicated weight of the test load	Confirm		
6.3.3		Mass of the test load:  For each discharge, the tare weight value subtracted from gross weight value is the net weight of the material discharged. A summation of the net weight values of all the discharges in the test load shall be the conventional true value of the mass of the test load	Confirm		

Report page ... / ...

Use this page to detail remarks from the checklist

## TEST REPORT

## Test equipment used for pattern evaluation

Application No: .....

Report date: .....

Pattern designation: .....

Manufacturer: .....

List all test equipment used in this report:

Configuration for test

Application No: .....

Report date: .....

Pattern designation: .....

Manufacturer: .....

Use this space for additional information relating to equipment configuration, interfaces, data rates, load cells, EMC protection options etc., for the instrument and/or simulator

Explanatory notes

Meaning of symbols:

- I = Indication  
I<sub>n</sub> = n<sup>th</sup> indication  
L = Load  
ΔL = Additional load to next changeover point  
P = I + 0.5 d - ΔL = Indication prior to rounding (digital indication)  
E = I - L or P - L = Error  
E<sub>0</sub> = Error calculated at zero  
E<sub>c</sub> = Corrected error  
mpe = Maximum permissible error (absolute value)  
EUT = Equipment under test

The name(s) or symbol(s) of the unit(s) used to express test results shall be specified in each form.

The white spaces in boxes in the headings of the report should always be filled in according to the following example:

	At start	At end	
Temp:	20.5	21.1	°C
Rel. h:			%
Date:	96:12:02	96:12:03	yy:mm:dd
Time:	16:00:05	16:30:05	hh:mm:ss

where:

Temp = temperature

Rel. h = relative humidity

"Date" in the test reports refers to the date on which the test was performed.

In the disturbance tests, faults greater than d are acceptable provided that they are detected and acted upon, or that they result from circumstances such that these faults shall not be considered as significant; an appropriate explanation shall be given in the column "Yes (remarks)".

Numbers in brackets refer to the corresponding subclauses of OIML R 107-1.

## Summary of test report

Application No: .....

Pattern designation: .....

R 107-2	Tests	Report page	Passed	Failed	Remarks
1	Zero-setting device				
2	Material tests				
3	Warm-up time				
4	Influence quantities				
4.1	Static temperature				
4.2	Damp heat, steady state				
4.3	Mains power supply voltage variations (AC)				
4.4	Battery power supply voltage variations (DC)				
5	Disturbances				
5.1	Voltage dips and short interruptions				
5.2	Electrical fast transients/burst immunity				
5.3	Electrostatic discharges				
5.4	Electromagnetic susceptibility				
6	Span stability				

## 1 Zero-setting device (R 107-1, 3.2.6, A.6.1)

Application No: .....  
 Pattern designation: .....  
 Observer: .....  
 Control scale interval (d): .....  
 Resolution during test: .....  
 (smaller than d)

	At start	At end
Temp:		°C
Rel. h:		%
Date:		yy:mm:dd
Time:		hh:mm:ss

## 1.1 Zero-setting modes (R 107-1, A.6.1.1)

	Present	Range tested	Accuracy tested
Nonautomatic			
Semi-automatic			
Auto-zero at switch-on			
Auto-zero at start of automatic operation			
Auto-zero as part of weighing cycle			

## 1.2 Range of zero-setting (R 107-1, A.6.1.2)

Positive range L <sub>1</sub>	Negative range L <sub>2</sub>	Range L <sub>1</sub> + L <sub>2</sub>	% of maximum load

Remarks:

## 1.3 Accuracy of zero-setting (R 107-1, A.6.1.3)

$\Delta L$	$E = 0.5 d - \Delta L$	$E/d$

Remarks:

## 1.4 Additional zero-setting modes

Application No: .....  
 Pattern designation: .....  
 Observer: .....  
 Control scale interval (d): .....  
 Resolution during test: .....  
 (smaller than d)

	At start	At end
Temp:		°C
Rel. h:		%
Date:		yy:mm:dd
Time:		hh:mm:ss

## 1.4.1 Test of additional zero-setting mode (R 107-1, A.6.1.1)

Zero-setting mode	
-------------------	--

## 1.4.1.1 Range of zero-setting (R 107-1, A.6.1.2)

$L_1$	$L_2$	$L_1 + L_2$	% of maximum load

## 1.4.1.2 Accuracy of zero-setting (R 107-1, A.6.1.3)

$\Delta L$	$E = 0.5 d - \Delta L$	$E/d$

## 1.4.2 Test of additional zero-setting mode (R 107-1, A.6.1.1)

Zero-setting mode	
-------------------	--

## 1.4.2.1 Range of zero-setting (R 107-1, A.6.1.2)

$L_1$	$L_2$	$L_1 + L_2$	% of maximum load

## 1.4.2.2 Accuracy of zero-setting (R 107-1, A.6.1.3)

$\Delta L$	$E = 0.5 d - \Delta L$	$E/d$

## 1.5 Zero offset interlock (R 107-1, 3.2.6, A.7.7)

Application No: .....

Pattern designation: .....

Observer: .....

Totalization scale interval ( $d_t$ ): .....Resolution during test:  
(smaller than  $d_t$ ) .....

	At start	At end
Temp:		°C
Rel. h:		%
Date:		yy:mm:dd
Time:		hh:mm:ss

Method of zero-setting:

Non auto or semi-auto

Auto

Positive offset:

Load applied after zeroing:		
Automatic operation	inhibited	
	not inhibited	

Negative offset:

Load removed after zeroing:		
Automatic operation	inhibited	
	not inhibited	

Remarks:

## 2 Material tests (R 107-1, 5.1.3.1, A.6.2)

## 2.1 Material testing (separate verification method) (R 107-1, 6.2, A.6.2.2)

Test 1

Application No: .....

At start

At end

Pattern designation: .....

Temp:

°C

Observer: .....

Rel. h:

%

Control scale interval (d): .....

Date:

yy:mm:dd

Totalization scale interval d<sub>t</sub>: .....

Time:

hh:mm:ss

Material: .....

Condition of material: .....

Nominal load: .....

Number of loads	
Indicated total at start T <sub>S</sub>	
Indicated total at end T <sub>F</sub>	
I = T <sub>F</sub> - T <sub>S</sub>	
Control instrument indication for total load L	
Error = $\frac{I - L}{L} \times 100 \text{ \%}$	

Remarks:

## 2.1 Material testing (separate verification method) (continued)

Test 2

Application No: .....

At start

At end

Pattern designation: .....

Temp:

°C

Observer: .....

Rel. h:

%

Control scale interval (d): .....

Date:

yy:mm:dd

Totalization scale interval  $d_t$ : .....

Time:

hh:mm:ss

Material: .....

Condition of material: .....

Nominal load: .....

Number of loads	
Indicated total at start $T_s$	
Indicated total at end $T_f$	
$I = T_f - T_s$	
Control instrument indication for total load L	
Error = $\frac{I - L}{L} \times 100 \text{ %}$	

Remarks:

## 2.1 Material testing (separate verification method) (continued)

Test 3

Application No:	.....	At start	At end
Pattern designation:	.....	Temp:	°C
Observer:	.....	Rel. h:	%
Control scale interval (d):	.....	Date:	yy:mm:dd
Totalization scale interval d <sub>t</sub> :	.....	Time:	hh:mm:ss
Material:	.....		
Condition of material:	.....		
Nominal load:	.....		

Number of loads	
Indicated total at start T <sub>S</sub>	
Indicated total at end T <sub>F</sub>	
I = T <sub>F</sub> - T <sub>S</sub>	
Control instrument indication for total load L	
Error = $\frac{I - L}{L} \times 100 \text{ \%}$	

Remarks:

## 2.1 Material testing (separate verification method) (continued)

Additional test

Application No: .....

At start

At end

Pattern designation: .....

Temp:

°C

Observer: .....

Rel. h:

%

Control scale interval (d): .....

Date:

yy:mm:dd

Totalization scale interval  $d_t$ : .....

Time:

hh:mm:ss

Material: .....

Condition of material: .....

Nominal load: .....

Number of loads	
Indicated total at start $T_s$	
Indicated total at end $T_f$	
$I = T_f - T_s$	
Control instrument indication for total load L	
Error = $\frac{I - L}{L} \times 100 \text{ %}$	

Remarks:

## 2.1 Material testing (separate verification method) (continued)

Additional test

Application No: .....

At start

At end

Pattern designation: .....

Temp:

°C

Observer: .....

Rel. h:

%

Control scale interval (d): .....

Date:

yy:mm:dd

Totalization scale interval d<sub>t</sub>: .....

Time:

hh:mm:ss

Material: .....

Condition of material: .....

Nominal load: .....

Number of loads	
Indicated total at start T <sub>S</sub>	
Indicated total at end T <sub>F</sub>	
I = T <sub>F</sub> - T <sub>S</sub>	
Control instrument indication for total load L	
Error = $\frac{I - L}{L} \times 100 \text{ \%}$	

Remarks:

## 2.2 Integral verification method (R 107-1, A.6.2.3)

#### 2.2.1 Integral verification method weighing test (see Note) (A.6.2.3.1 & A.6.2.5)

Application No: .....  
Pattern designation: .....  
Observer: .....  
Control scale interval (d): .....  
Resolution during test:  
(smaller than d) .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Automatic zero-setting device is:

- Non-existent     Not in operation     Out of working range     In operation

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Note: This test is only part of the material tests when the integral weighing method is used for material tests. It is then conducted prior to the actual material test

Remarks:

#### 2.2.2 Material testing (integral verification method) (R 107-1, 5.1.3.1, 6.3, A.6.2.3)

## Test 1

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval  $d_t$ : .....

Material: .....

Condition of material: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

HOPPER CONTENTS STATIC WEIGHING						INDICATED TOTAL
Indication I	Add. load $\Delta L$	Indication prior to rounding $P = I + 0.5 d - \Delta L$	Cal. error E	Corrected indication $I_c = P - E$	Load weight $L = I_{CL} - I_{CD}$	At start $T_s$
Loaded				$I_{CL}$		
Discharged				$I_{CD}$		
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Error =	$\frac{T_F - T_s - \Sigma L}{\Sigma L} \times 100 \%$			$\Sigma L$ (total load)		At end $T_F$
Error =						

### 2.2.2 Material testing (integral verification method) (continued)

## Test 2

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval  $d_t$ : .....

Material: .....

Condition of material: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

HOPPER CONTENTS STATIC WEIGHING						INDICATED TOTAL
Indication I	Add. load $\Delta L$	Indication prior to rounding $P = I + 0.5 d - \Delta L$	Cal. error E	Corrected indication $I_C = P - E$	Load weight $L = I_{CL} - I_{CD}$	
Loaded				$I_{CL}$		
Discharged				$I_{CD}$		
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
At end $T_F$						

### 2.2.2 Material testing (integral verification method) (continued)

Test 3

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval  $d_t$ : .....

**Material:** .....

Condition of material: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

HOPPER CONTENTS STATIC WEIGHING						INDICATED TOTAL
Indication I	Add. load $\Delta L$	Indication prior to rounding $P = I + 0.5 d - \Delta L$	Cal. error E	Corrected indication $I_C = P - E$	Load weight $L = I_{CL} - I_{CD}$	
Loaded				$I_{CL}$		
Discharged				$I_{CD}$		
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
At end $T_F$						

### 2.2.2 Material testing (integral verification method) (continued)

Test 4

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval  $d_t$ : .....

Material: .....

Condition of material: .....

Nominal load: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

HOPPER CONTENTS STATIC WEIGHING						INDICATED TOTAL
Indication I	Add. load $\Delta L$	Indication prior to rounding $P = I + 0.5 d - \Delta L$	Cal. error E	Corrected indication $I_C = P - E$	Load weight $L = I_{CL} - I_{CD}$	
Loaded				$I_{CL}$		
Discharged				$I_{CD}$		
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
At end $T_F$						

### 2.2.2 Material testing (integral verification method) (continued)

Test 5

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval  $d_t$ : .....

**Material:** .....

Condition of material: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

HOPPER CONTENTS STATIC WEIGHING						INDICATED TOTAL
Indication I	Add. load $\Delta L$	Indication prior to rounding $P = I + 0.5 d - \Delta L$	Cal. error E	Corrected indication $I_C = P - E$	Load weight $L = I_{CL} - I_{CD}$	
Loaded				$I_{CL}$		At start $T_s$
Discharged				$I_{CD}$		
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
Loaded						
Discharged						
At end $T_f$						

## 3 Warm-up time (R 107-1, 4.3.5, A.7.1)

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Resolution during test:  
(smaller than d) .....

	At start	At end
Temp:		°C
Rel. h:		%
Date:		yy:mm:dd
Time:		hh:mm:ss

Duration of disconnection  
before test: .....

Automatic zero-setting device is:

Non-existent

Not in operation

Out of working range

In operation

$$E = I + 0.5 d - \Delta L - L$$

 $E_0$  = error calculated at zero or near zero (unloaded) $E_L$  = error calculated at load (loaded)

Time (*)	Load	Indication I	Add. load $\Delta L$	Error E	$E_L - E_0$
-------------	------	-----------------	-------------------------	------------	-------------

Unloaded	0 min				$E_{0l} =$
Loaded					$E_L =$

Unloaded	5 min				$E_0 =$
Loaded					$E_L =$

Unloaded	15 min				$E_0 =$
Loaded					$E_L =$

Unloaded	30 min				$E_0 =$
Loaded					$E_L =$

(\*) Counted from the moment an indication has first appeared

Remarks:

#### 4 Influence quantities (R 107-1, 2.7, A.8 & A.8.3)

#### 4.1 Static temperatures (R 107-1, A.8.3.1, A.8.1 & A.8.2)

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval  $d_t$ : .....  
.....

Automatic zero-setting is:

 Non-existent     Not in operation     Out of working range     In operation

## Test 1 - Static temperature, reference 20 °C

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

## **Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)

**Result sheet C** (R 107-1, A.8.2.2)

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Remarks:

Test 2 - Static temperature, specified high (      °C)

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Load L	Indication I		Add. load $\Delta L$		Error E		Corrected error $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
(*)					(*)				

**Result sheet B (R 107-1, A.8.2.3)**

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Remarks:

Test 3 - Static temperature, specified low (      °C)

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Load L	Indication I		Add. load $\Delta L$		Error E		Corrected error $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
(*)					(*)				

**Result sheet B (R 107-1, A.8.2.3)**

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Remarks:

#### Test 4 - Static temperature, 5 °C

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

## **Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_0$  with  $E_0$  = error calculated at or near zero (\*)

## **Result sheet B (R 107-1, A.8.2.3)**

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test (   )	At end of test (   )	Max deviation observed (except for non-recordable transients)

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Remarks:

Test 5 - Static temperature, reference 20 °C

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Load L	Indication I		Add. load ΔL		Error E		Corrected error $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
(*)					(*)				

**Result sheet B (R 107-1, A.8.2.3)**

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Remarks:

## 4.2 Damp heat, steady state (R 107-1, 4.3.3, A.8.3.2 &amp; A.8.1 &amp; A.8.2)

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval d<sub>t</sub>: .....

Automatic zero-setting is:

- Non-existent     Not in operation     Out of working range     In operation

Initial test at reference temperature of 20 °C and relative humidity of 50 %

	At start	After 3 hrs	At end	
Temp:				°C
Rel. h:				%
Date:				yy:mm:dd
Time:				hh:mm:ss

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

 $E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Load L	Indication I		Add. load ΔL		Error E		Corrected error E <sub>c</sub>		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
(*)					(*)				

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)

**Result sheet C** (R 107-1, A.8.2.2)

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Test at upper limit temperature (      °C), relative humidity of 85 %

	At start	After 2 days	At end
Temp:			°C
Rel. h:			%
Date:			yy:mm:ss
Time:			hh:mm:ss

## Result sheet A

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

## **Result sheet B (R 107-1, A.8.2.3)**

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test (   )	At end of test (   )	Max deviation observed (except for non-recordable transients)

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Final test at reference temperature of 20 °C and relative humidity of 50 %

	At start	After 2 h	At end	
Temp:				°C
Rel. h:				%
Date:				yy:mm:dd
Time:				hh:mm:ss

### Result sheet A

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

$E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Load L	Indication I		Add. load ΔL		Error E		Corrected error $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
(*)					(*)				

### Result sheet B (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Totalization indication		
At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Error $T_c - T_I$ ( )

Remarks:

## 4.3 Mains power supply voltage variation (AC) (R 107-1, 2.7.2, 4.3.3 &amp; A.8.3.3)

Application No:	.....	At start	At end
Pattern designation:	.....	Temp:	°C
Observer:	.....	Rel. h:	%
Control scale interval (d):	.....	Date:	yy:mm:dd
Totalization scale interval d <sub>t</sub> :	.....	Time:	hh:mm:ss

Automatic zero-setting is:

- Non-existent     Not in operation     Out of working range     In operation

Marked nominal voltage, U<sub>n</sub>, or voltage range:    VReference voltage: (\*\*):    V**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

 $E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Voltage	Load L	Indication I	Add. load $\Delta L$	Error E	Corrected error $E_c$
Reference voltage				(*)	
Reference voltage - 15 %					
Reference voltage +10 %					
Reference voltage					

(\*\*) The reference voltage shall be as defined in IEC 1000-4-11 (1994)

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Voltage	Totalization indication		
	At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)
Reference voltage			
Reference voltage -15 %			
Reference voltage +10 %			
Reference voltage			

**Result sheet C** (R 107-1, A.8.2.2)

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage	Static load	Calculated change in totalization $T_c$	Totalization before adding load $T_b$	Totalization after adding load $T_a$	Indicated change in totalization $T_I = T_a - T_b$	Error $T_c - T_I$
Reference voltage						
Reference voltage -15 %						
Reference voltage +10 %						
Reference voltage						

Remarks:

## 4.4 Battery power supply voltage variation (DC) (R 107-1, 2.7.3, 4.3.3 &amp; A.8.3.4)

Application No:	.....	At start	At end
Pattern designation:	.....	Temp:	°C
Observer:	.....	Rel. h:	%
Control scale interval (d):	.....	Date:	yy:mm:dd
Totalization scale interval d <sub>t</sub> :	.....	Time:	hh:mm:ss

Automatic zero-setting is:

- Non-existent     Not in operation     Out of working range     In operation

Marked nominal voltage:    VLower limit voltage: (\*\*\*)    V**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

$$E = I + 0.5 d - \Delta L - L$$

 $E_c = E - E_o$  with  $E_o$  = error calculated at or near zero (\*)

Voltage	Load L	Indication I	Add. load $\Delta L$	Error E	Corrected error $E_c$
Nominal voltage				(*)	
Lower limit voltage					
Nominal voltage					

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Voltage	Totalization indication		
	At start of test ( )	At end of test ( )	Max deviation observed (except for non-recordable transients)
Nominal voltage			
Lower limit voltage			
Nominal voltage			

(\*\*) The lower limit voltage shall be the voltage at which the EUT clearly ceases to function + 2 % of this voltage

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage	Static load	Calculated change in totalization $T_c$	Totalization before adding load $T_b$	Totalization after adding load $T_a$	Indicated change in totalization $T_I = T_a - T_b$	Error $T_c - T_I$
( )	( )	( )	( )	( )	( )	( )
Nominal voltage						
Lower limit						
Nominal voltage						

Remarks:

## 5 Disturbances (R 107-1, 4.1.2 &amp; 4.3.4 &amp; A.8 &amp; A.8.4)

## 5.1 Voltage dips and short interruptions (R 107-1, 4.1.2 &amp; 4.3.4 &amp; A.8.4.1)

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval d<sub>t</sub>: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Automatic zero-setting is:

- Non-existent     Not in operation     Out of working range     In operation

Marked nominal voltage, U<sub>n</sub>, or voltage range:  VReference voltage: (\*)  V

Pre-test information

Disturbance parameters			
Amplitude % of U <sub>n</sub>	Duration cycles	Number of disturbances	Repetition interval (s)
0	0.5	10	
50	1	10	

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

Disturbance				Significant fault
Amplitude % of U <sub>n</sub>  (other parameters as pre-test information)	Static load  ( )	Indication I  ( )	No	
Without disturbance				Yes (remarks)
0				
50				

(\*) The reference voltage shall be as defined in IEC 1000-4-11 (1994)

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Disturbance	Result		
	Totalization indication		Significant fault
Amplitude % of $U_n$	At start of test	At end of test	
(other parameters as pre-test information)	( )	( )	No
Without disturbance			
0			
50			

**Result sheet C** (R 107-1, A.8.2.2)

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbance	Result						
	Load	Calculated change in totalization $T_c$	Totalization before adding load $T_b$	Totalization after adding load $T_a$	Indicated change in totalization $T_I = T_a - T_b$	Significant fault	
Amplitude % of $U_n$	( )	( )	( )	( )	( )	No	Yes (remarks)
(other parameters as pre-test information)							
Without disturbance							
0							
50							

Note 1: If significant faults are detected and acted upon, the test point at which this occurs shall be recorded

Note 2: If the EUT fails the test point at which this occurs shall be recorded

Remarks:

## 5.2 Electrical fast transients/burst immunity (R 107-1, 4.1.2 &amp; 4.3.4 &amp; A.8.4.2)

## 5.2.1 Power lines

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval d<sub>t</sub>: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Automatic zero-setting is:

- Non-existent     Not in operation     Out of working range     In operation

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

Power supply lines: test voltage 1 kV, duration of the test 1 minute at each polarity

Disturbance connexion and polarity		Result			
		Load ( )	Indication I ( )	Significant fault	
				No	Yes (remarks)
without disturbance					
Live	pos				
↓					
ground	neg				
without disturbance					
Neutral	pos				
↓					
ground	neg				
without disturbance					
Protective earth	pos				
↓					
ground	neg				

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Disturbance connection and polarity		Result			
		Totalization indication		Significant fault	
		At start of test ( )	At end of test ( )	No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

**Result sheet C** (R 107-1, A.8.2.2)

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbance connection and polarity		Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Result	
							$T_c - T_I$	Significant fault
without disturbance								
Live ↓ ground	pos							
	neg							
without disturbance								
Neutral ↓ ground	pos							
	neg							
without disturbance								
Protective earth ↓ ground	pos							
	neg							

Note 1: If significant faults are detected and acted upon, the test point at which this occurs shall be recorded

Note 2: If the EUT fails the test point at which this occurs shall be recorded

Remarks:

## 5.2 Electrical fast transients/burst immunity (continued)

## 5.2.2 I/O circuits and communication lines

Application No: .....  
 Pattern designation: .....  
 Observer: .....  
 Control scale interval (d): .....  
 Totalization scale interval d<sub>t</sub>: .....

	At start	At end
Temp:		°C
Rel. h:		%
Date:		yy:mm:dd
Time:		hh:mm:ss

Automatic zero-setting is:

- Non-existent     Not in operation     Out of working range     In operation

I/O signals, data and control lines: test voltage 0.5 kV, duration of the test 1 minute at each polarity

Explain or make a sketch indicating where the clamp is located on the cable: if necessary, use an additional page

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

Cable/Interface (C/I) and polarity	Load ( )	Indication I ( )	Result	
			Significant fault	
			No	Yes (remarks)
without disturbance				
C/I,1	pos			
	neg			
without disturbance				
C/I,2	pos			
	neg			
without disturbance				
C/I,3	pos			
	neg			
without disturbance				
C/I,4	pos			
	neg			
without disturbance				
C/I,5	pos			
	neg			
without disturbance				
C/I,6	pos			
	neg			

Note: The cell references C/I,1 to C/I,6 should be used to cross reference the cable or interface between Tables A and B

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Cable/Interface (C/I) and polarity	Totalization indication			Result	
	At start of test		( )	Significant fault	
	( )	No		Yes (remarks)	
without disturbance					
C/I,1	pos				
	neg				
without disturbance					
C/I,2	pos				
	neg				
without disturbance					
C/I,3	pos				
	neg				
without disturbance					
C/I,4	pos				
	neg				
without disturbance					
C/I,5	pos				
	neg				
without disturbance					
C/I,6	pos				
	neg				

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Cable/interface (C/I) and polarity		Result						
		Load ( )	Calculated change in totalization $T_c$ ( )	Totalization before adding load $T_b$ ( )	Totalization after adding load $T_a$ ( )	Indicated change in totalization $T_I = T_a - T_b$ ( )	Significant fault $T_c - T_I$	
C/I,1	pos						No	Yes (remarks)
	neg							
without disturbance								
C/I,2	pos							
	neg							
without disturbance								
C/I,3	pos							
	neg							
without disturbance								
C/I,4	pos							
	neg							
without disturbance								
C/I,5	pos							
	neg							
without disturbance								
C/I,6	pos							
	neg							

Note 1: If significant faults are detected and acted upon, the test point at which this occurs shall be recorded

Note 2: If the EUT fails the test point at which this occurs shall be recorded

Note 3: Explain, or make a sketch indicating where the clamp is located on the cable; if necessary, use an additional page

Remarks:

## 5.3 Electrostatic discharges (R 107-1, 4.1.2 &amp; 4.3.4 &amp; A.8.4.3)

## 5.3.1 Direct application

Application No:	.....	At start	At end
Pattern designation:	.....	Temp:	°C
Observer:	.....	Rel. h:	%
Control scale interval (d):	.....	Date:	yy:mm:dd
Totalization scale interval d <sub>t</sub> :	.....	Time:	hh:mm:ss

Automatic zero-setting is:

Non-existent     Not in operation     Out of working range     In operation

Contact discharges     Paint penetration

Air discharges    Polarity: (\*)  pos     neg

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

Discharges			Result			
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Load ( )	Indication I ( )	Significant fault	
					No	Yes (remarks)
without disturbance						
2						
4						
6						
8 (air discharges)						

(\*) IEC 1000-4-2 specifies that the test should be conducted at the most sensitive polarity

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Discharges			Result			
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Totalization indication		Significant fault	
			At start of test ( )	At end of test ( )	No	Yes (remarks)
without disturbance						
2						
without disturbance						
4						
without disturbance						
6						
without disturbance						
8 (air discharges)						

**Result sheet C** (R 107-1, A.8.2.2)

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbance			Result						
				Totalization indication					
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Load ( )	Calculated change $T_c$	Before adding load $T_b$	After adding load $T_a$	Indicated change $T_I$	Significant fault $T_c - T_I$	
								No	Yes (remarks)
without disturbance									
2									
without disturbance									
4									
without disturbance									
6									
without disturbance									
8 (air discharges)									

Note 1: If significant faults are detected and acted upon, the test point at which this occurs shall be recorded

Note 2: If the EUT fails the test point at which this occurs shall be recorded

Remarks:

## 5.3 Electrostatic discharges (continued)

## 5.3.2 Indirect application (contact discharge only)

Application No: .....

Pattern designation: .....

Observer: .....

Control scale interval (d): .....

Totalization scale interval d<sub>t</sub>: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Automatic zero-setting is:

Non-existent     Not in operation     Out of working range     In operation

Polarity: (\*)  pos     neg

**Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

Horizontal coupling plane

Discharges			Result		
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Load ( )	Indication I ( )	Significant fault
			No	Yes (remarks)	
without disturbance					
2					
4					
6					

Vertical coupling plane

Discharges			Result		
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Load ( )	Indication I ( )	Significant fault
			No	Yes (remarks)	
without disturbance					
2					
4					
6					

(\*) IEC 1000-4-2 specifies that the test should be conducted with the most sensitive polarity

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Horizontal coupling plane

Discharges			Result			
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Totalization indication		Significant fault	
			At start of test ( )	At end of test ( )	No	Yes (remarks)
without disturbance						
2						
without disturbance						
4						
without disturbance						
6						

Vertical coupling plane

Discharges			Result			
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Totalization indication		Significant fault	
			At start of test ( )	At end of test ( )	No	Yes (remarks)
without disturbance						
2						
without disturbance						
4						
without disturbance						
6						

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Horizontal coupling plane

Disturbance			Result						
				Totalization indication					
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Load ( )	Calculated change $T_c$	Before adding load $T_b$	After adding load $T_a$	Indicated change $T_I$	Significant fault $T_c - T_I$	
without disturbance									
2			( )					No	Yes (remarks)
without disturbance									
4			( )					No	Yes (remarks)
without disturbance									
6			( )					No	Yes (remarks)

Vertical coupling plane

Disturbance			Result						
				Totalization indication					
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Load ( )	Calculated change $T_c$	Before adding load $T_b$	After adding load $T_a$	Indicated change $T_I$	Significant fault $T_c - T_I$	
without disturbance									
2			( )					No	Yes (remarks)
without disturbance									
4			( )					No	Yes (remarks)
without disturbance									
6			( )					No	Yes (remarks)

Note 1: If significant faults are detected and acted upon, the test point at which this occurs shall be recorded

Note 2: If the EUT fails the test point at which this occurs shall be recorded

Remarks:

5.3 Electrostatic discharges (continued)

Specification of test points of EUT (direct application), e.g. by photos or sketches

a) Direct application

Contact discharges:

Air discharges:

b) Indirect application

## 5.4 Electromagnetic susceptibility (R 107-1, 4.1.2 &amp; 4.3.4 &amp; A.8.4.4)

Application No: .....

At start

At end

Pattern designation: .....

Temp:

°C

Observer: .....

Rel. h:

%

Control scale interval (d): .....

Date:

yy:mm:dd

Totalization scale interval d<sub>t</sub>: .....

Time:

hh:mm:ss

Rate of sweep: **Result sheet A**

To be used in conjunction with result sheet B when the integral control device is used to determine the error

Disturbance				Result			
Antenna	Frequency range (MHz)	Polarization	Facing EUT	Load ( )	Indication I ( )	Significant fault	
						No	Yes (remarks)
without disturbance							
	Vertical	Front					
		Right					
		Left					
		Rear					
	Horizontal	Front					
		Right					
		Left					
		Rear					
	Vertical	Front					
		Right					
		Left					
		Rear					
	Horizontal	Front					
		Right					
		Left					
		Rear					

**Result sheet B** (R 107-1, A.8.2.3)

To be used in conjunction with result sheet A to record the retained totalization indication

Disturbance				Result			
Antenna	Frequency range (MHz)	Polarization	Facing EUT	Load	Totalization indication		Significant fault
					( )	( )	
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				

**Result sheet C (R 107-1, A.8.2.2)**

To be used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

				Result							
Antenna	Frequency	Polarization	Facing EUT		Totalization						
				Load	Calculated change T <sub>c</sub>	Before adding load T <sub>b</sub>	After adding load T <sub>a</sub>	Indicated change T <sub>I</sub>	T <sub>c</sub> - T <sub>I</sub>	No	Yes (remarks)
without disturbance											
		Vertical	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Horizontal	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Vertical	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Horizontal	Front								
			Right								
			Left								
			Rear								

Frequency range: 26–1000 MHz

Field strength: 3 V/m

Modulation: 80 % AM, 1 kHz sine wave

Note 1: If significant faults are detected and acted upon, the test point at which this occurs shall be recorded

Note 2: If the EUT fails the test point at which this occurs shall be recorded

Remarks:

5.4 Electromagnetic susceptibility (continued)

Provide a description of the set-up of the EUT, e.g. by photos or sketches

## 6 Span stability (R 107-1, 4.4.3, A.9)

Application No: .....

Pattern designation: .....

Control scale interval (d): .....

Resolution during test:  
(smaller than d) .....

Automatic zero-setting device is:

- Non-existent     Not in operation     Out of working range

Test load = 

## Measurement No. 1: Initial measurement

Observer: .....  
Location: .....

	At start	At end
Temp:		°C
Rel. h:		%
Date:		yy:mm:dd
Time:		hh:mm:ss

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
See remarksAverage error = average ( $E_L - E_o$ ) =  $(E_L - E_o)_{\max} - (E_L - E_o)_{\min} =$  0.1 d = If  $*(E_L - E_o)_{\max} - (E_L - E_o)_{\min} * \leq 0.1 d$ , the loading and reading will be sufficient for each of the subsequent measurements; if not, five loadings and readings shall be performed at each measurement

Remarks:

## 6 Span stability (continued)

## Subsequent measurements

For each of the subsequent measurements (at least 7), indicate on the line "conditions of the measurement", as appropriate, if the measurement has been performed:

- after the temperature test, the EUT having been stabilized for at least 16 h;
- after the humidity test, the EUT having been stabilized for at least 16 h;
- after the EUT has been disconnected from the mains for at least 8 h and then stabilized for at least 5 h;
- after any change in the test location;
- under any other specific condition.

## Measurement No. 2:

		At start	At end	
Observer:	.....			°C
Location:	.....			%
Date:	.....			yy:mm:dd
Time:	.....			hh:mm:ss

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
See remarks

If five loadings and readings have been performed:

$$\begin{aligned} \text{Average error} &= \text{average } (E_L - E_o) \\ &= \boxed{\phantom{000}} \end{aligned}$$

Remarks:

## 6 Span stability (continued)

Measurement No. 3:

Observer: .....  
 Location: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Conditions of the measurement:

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
 See remarks

If five loadings and readings have been performed:

$$\begin{aligned} \text{Average error} &= \text{average } (E_L - E_o) \\ &= \boxed{\phantom{000}} \end{aligned}$$

Remarks:

Measurement No. 4:

Observer: .....  
 Location: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Conditions of the measurement:

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
 See remarks

If five loadings and readings have been performed:

$$\begin{aligned} \text{Average error} &= \text{average } (E_L - E_o) \\ &= \boxed{\phantom{000}} \end{aligned}$$

Remarks:

## 6 Span stability (continued)

Measurement No. 5:

Observer: .....  
 Location: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Conditions of the measurement:

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
 See remarks

If five loadings and readings have been performed:

$$\begin{aligned} \text{Average error} &= \text{average } (E_L - E_o) \\ &= \boxed{\phantom{000}} \end{aligned}$$

Remarks:

Measurement No. 6:

Observer: .....  
 Location: .....

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Conditions of the measurement:

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
 See remarks

If five loadings and readings have been performed:

$$\begin{aligned} \text{Average error} &= \text{average } (E_L - E_o) \\ &= \boxed{\phantom{000}} \end{aligned}$$

Remarks:

## 6 Span stability (continued)

Measurement No. 7:

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Conditions of the measurement:

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
See remarks

If five loadings and readings have been performed:

$$\text{Average error} = \text{average } (E_L - E_o) \\ = \boxed{\phantom{000}}$$

Remarks:

Measurement No. 8:

	At start	At end	
Temp:			°C
Rel. h:			%
Date:			yy:mm:dd
Time:			hh:mm:ss

Conditions of the measurement:

$$E_o = I_o + 0.5 d - \Delta L_o - L_o \quad E_L = I_L + 0.5 d - \Delta L - L$$

	Indication of zero ( $I_o$ )	Add. load ( $\Delta L_o$ )	$E_o$	Indication of load ( $I_L$ )	Add. load ( $\Delta L$ )	$E_L$	$E_L - E_o$	Corrected value (*)
1								
2								
3								
4								
5								

(\*) When applicable, necessary corrections resulting from variations of temperature, pressure, etc.  
See remarks

If five loadings and readings have been performed:


$$\text{Average error} = \text{average } (E_L - E_o) \\ = \boxed{\phantom{000}}$$

Remarks:

6 Span stability (continued)

Application No: .....

Pattern designation: .....



Maximum allowable variation: